

Certificate

Norshield AS hereby verify that the mountain halls have been controlled according to the standards:

2202.2.4/SHOPCV/P-82

Measuring results inside shielded area show an insertion loss of 83 dB.

MIL-STD 285

Additional screened doors inside the hall were measured at the frequencies 156 kHz to 10 MHz according to MIL-STD 285 with the results: Insertion loss above 80 dB.

Os i Østerdalen 20. January 03

Norshield AS



Torstein Hernes

